

2020 Lead and Copper Data

Lead and copper testing is performed on a triannual basis (every 3 years). The most current results are from 2020 and are listed below. The results shown include data collected from 20 primary sample sites that are registered with the Illinois Environmental Protection Agency (IEPA).

Copper levels must be above 1300 ppb (parts per billion) for a minimum of 2 sites before the IEPA requires further action. The same rule applies for Lead, with the exception that the minimum concentration of 15 ppb (parts per billion) is needed for further action.

Our next IEPA sampling and testing will be performed between June 1, 2023, and September 30, 2023. If you have any questions regarding lead or copper in your drinking water, please contact public works at (630)773-2455.

- Ppb= Parts Per Billion
- 1ppb=1 ug/l

2020 Results

			Copper Result	Lead Result
321	W.	Bloomingtondale Rd.	0	0
360	W.	Bloomingtondale Rd.	0	0
215	N.	Elm St.	0	0
226	N.	Elm St.	0	0
321	N.	Elm St.	0	0
328	N.	Elm St.	0	0
105	S.	Maple St.	0	0
115	S.	Maple St.	0	0
116	S.	Maple St.	0	0
125	S	Maple St.	0	0
200	S.	Maple St.	0	0
221	S.	Maple St.	0	2.86
242	S.	Maple St.	0	0
319	S.	Maple St.	0	0
333	S.	Maple St.	0	0
350	S.	Maple St.	123	2.16
108	S.	Walnut Ave.	0	0
200	S.	Walnut Ave.	0	0
210	S.	Walnut Ave.	359	0
224	S.	Walnut Ave.	0	0